

Burgess, Dave

From: David Carter <dcarter@rybekconstruction.com>
Sent: Thursday, September 26, 2019 1:52 PM
To: Jones, Wesley
Cc: Burgess, Dave; Glessner, Donald; Shelton, Christina
Subject: Statue install

Wesley,

I have reviewed both options for the statue install including consulting with my window sub.

Option one: Remove exterior window to crane/rig the statue through the opening.

Option two: Remove and replace mosaic floor pieces and partially disassemble and reassemble the interior door and jamb.

Option one: My concerns are coordinating the crane company and window removal along with any unknowns such as repairs to any window bucks and repairs on the inside drywall or plaster. If we can do it all in one day that would be great but I think we should plan to remove the window and count on repairs board up the window opening and have the crane install the second day.

The window company can return the afternoon of day two to reinstall the window.

That's two mobilizations for the window company but it gives us time for the unknowns. Without access (seeing the condition of the inside window opening)

I would budget \$3,000.00 to \$5,000.00. Crane and rigging by others.

Option two: My concerns here are many. The mosaics and the door jamb would be extremely difficult to disassemble and reassemble to look like the original.

In short its not a viable option for me I would have to pass on this one.

--

David Carter

Rybek Construction Inc.

CBC 1252394

561-762-7456

dcarter@rybekconstruction.com

Burgess, Dave

From: Gina Waterman <watermanconstructioncorp@gmail.com>
Sent: Wednesday, October 9, 2019 6:13 PM
To: Burgess, Dave
Subject: Historical Courthouse Mosaic Tile Removal for Statue

Hello Mr. Burgess,

Per your meeting with Ted regarding the tile removal in the Historical Courthouse, our professional opinion of removing the mosaic tile and reusing is not an option. The tile is so old and the likelihood of it coming up in reusable shape and not retaining a lot of the thin set on the back is highly unlikely. And, with the age of the tile, matching it would be virtually impossible. We do not recommend trying this endeavor and we decline to bid.

Thank you for your time. Please let us know if there is anything else we can help you with.

Sincerely,

Gina Waterman
Waterman Construction Corporation
352-669-1033

Burgess, Dave

From: Ryan Fitzgerald <ryan@rfc95.com>
Sent: Thursday, October 10, 2019 3:46 PM
To: Burgess, Dave; Ryan Fitzgerald
Subject: Historical Courthouse Tile Removal

Dave,

I appreciate the invitation to look at removing the tile off of the courthouse floor. I have thought long and hard about it and I am not interested in this project. I appreciate the historical aspect of this building and I do not feel there is a safe way to remove and re-install the tile. My suggestion would be lay (1) layer of 1/4" steel over (2) layers of 3/4" plywood fastened to 4"x4" laid on 1 foot centers to help distribute the weight. I could reach out to an engineer to help design an option if you would like. Please let me know if I can help in any way.

Sincerely,

P. Ryan Fitzgerald

President

Ryan Fitzgerald Construction Inc.

P.O. Box 526

Mount Dora, FL 32756

Office # 352-223-2879

Mobile# 352-267-7067

ryan@rfc95.com